


.....

# Sidera Environmental, Inc.

The Quarterly Visual Observations of Unauthorized Non-Storm Water Discharges (NSWDs) are required each quarter of each Permit Year, in July-September, October-December, January-March and April-June and included in the Annual Report submitted to your Regional Water Quality Control Board (RWQCB). Unauthorized NSWDs are discharges, such as wash and rinse waters, not meeting the Authorized NSWDs conditions. All drainage areas of the facility shall be observed for current and prior unauthorized NSWDs. Each source, impacted drainage area and discharge location must be identified and observed. Only NSWDs that reach storm drain inlets or discharge locations are reported. The visual observations are conducted during dry weather and during scheduled facility operating hours. Unauthorized NSWDs that can not be eliminated within 90 days of observations must be reported the Regional Water Quality Control Board.

The visual observations shall describe the NSWDs characteristics, which include whether the discharge:

- 
1. Was clear or cloudy.
  2. Was discolored.
  3. Was causing staining.
  4. Contained floating objects.
  5. Had an oil sheen.
  6. Had odors, etc.

Form 3 must record if Unauthorized Non-Storm Water Discharges (or indications of prior discharges) were observed during the quarter and if yes, described on reverse side the name, source and location, characteristics at the source, drainage area and the discharge location. The corrective actions to eliminate Unauthorized Non-Storm Water Discharges and clean the impacted drainage areas must also be described.